



## **ELECTRICAL APPLIANCE TEST & INSPECTION REPORT**

### **SATURN SOUND SYSTEM**

**44 HIGH STREET  
SUTTON  
CB6 2RB**

**30 June 2011**

**Head Office and National Control Centre:  
SandS House  
24 Maldon Road  
Wisbech  
Cambridgeshire  
PE13 3SR**

**Telephone: 0800 84 888 22  
Fax: 01945 738 101  
[e-mail: service@purepat.com](mailto:service@purepat.com)**



# Electrical Portable Appliance Inspection & Testing

## **ELECTRICAL SAFETY ADVICE**

Thank you for choosing NSS Pure-PAT to carry out your Electrical Portable Appliance Testing.

Please be aware that although we have Inspected and Tested the appliances on the enclosed Test & Inspection schedule there are still further precautions you should take to minimise the risk of any appliance causing a fire or electric shock.

- **IMPORTANT: Integrity of Fixed Electrical Wall Sockets**

Part of the PAT Testing procedure is to test the earth continuity of appliances that require to be continuously earthed. The earth continuity of an appliance is a very important built in safety feature that should take away the risk of a person receiving

This safety feature can only work correctly providing the earth connection to the fixed wall socket is also properly connected otherwise there is a risk of an electric shock even if the actual appliance has been passed as safe.

Fixed wall sockets can have as many as 17 different fault combinations, therefore if you have not had the wall sockets tested within the past three years we would recommend that they are tested on our next visit. If you require any help or advice please

- **Remember Water and Electricity are not a safe combination!**

In areas such as kitchens and staff rooms it is imperative that water does not come into contact with any electrical current – always ensure that your hands are dry before connecting or switching on any electrical appliance – this includes the sockets and

- **Extension Leads**

Extension leads that are used in the workplace should have a Residual Current Device (RCD) permanently fitted if the extension lead is more than 15 metres in length.

Do not use high energy Fan Heaters or Radiators in multi-socket extension leads – the maximum combined wattage of all appliances in multi-socket extension leads should not exceed 3000 watts.

It is not good practice to have extension leads sited on floors or anywhere near where water or liquid has a high risk of spillage.

Coiled extension leads generate heat – the greater the coil the greater the heat. Coiled extension leads should NOT be used continuously - far better to have a made to measure or fully unwound lead than a coiled lead.

- **FAILED or Damaged Appliances**

On NO account should you continue to use any damaged or faulty electrical appliances that have failed our tests – you are risking the possibility of a fire or electric shock.

The above are just a small sample of measures that can be taken to ensure the safety of everyone who comes into contact with electrical appliances.

# PORTABLE APPLIANCE TESTING REPORT



**NSS Pure-PAT Electrical Testing**  
 24 Maldon Road,  
 Wisbech,  
 Cambridgeshire PE13 3SR  
 Telephone: 01945 489 641  
 e-mail: service@purepat.com

**REPORT NO.:**

**11/3006**

**DATE:**

**30 June 2011**

**SATURN SOUND SYSTEM  
 44 HIGH STREET  
 SUTTON  
 CB6 2RB**

ID NO.	DESCRIPTION	CLASS	VISUAL INSPECTION	TEST		Functional Check	DATE OF NEXT TEST	PASS or FAIL	COMMENTS
				EARTH	INSULATION				
				Ohms	Mohms				
19477	LIGHT UNIT	1	PASS	0.02	>200	PASS	30/JUNE/2012	PASS	
19478	LIGHT UNIT	1	PASS	0.07	>200	PASS	30/JUNE/2012	PASS	
19479	LIGHT UNIT	1	PASS	0.10	>200	PASS	30/JUNE/2012	PASS	
19480	LIGHT UNIT	1	PASS	0.08	>200	PASS	30/JUNE/2012	PASS	
19481	SPOT LIGHT	2	PASS		>200	PASS	30/JUNE/2012	PASS	
19482	SPOT LIGHT	2	PASS		>200	PASS	30/JUNE/2012	PASS	
19483	MALE FEMALE IEC POWER LEAD	1	PASS	0.09	>200	PASS	30/JUNE/2012	PASS	
19484	IEC POWER LEAD	1	PASS	0.02	>200	PASS	30/JUNE/2012	PASS	
19485	IEC POWER LEAD	1	PASS	0.07	>200	PASS	30/JUNE/2012	PASS	
19486	IEC POWER LEAD	1	PASS	0.03	>200	PASS	30/JUNE/2012	PASS	
19487	4 GANG EXTENSION LEAD	1	PASS	0.08	>200	PASS	30/JUNE/2012	PASS	
19488	4 GANG EXTENSION LEAD	1	PASS	0.06	>200	PASS	30/JUNE/2012	PASS	
19489	MALE FEMALE IEC POWER LEAD	1	PASS	0.08	>200	PASS	30/JUNE/2012	PASS	
19490	MALE FEMALE IEC POWER LEAD	1	PASS	0.07	>200	PASS	30/JUNE/2012	PASS	
19491	MALE FEMALE IEC POWER LEAD	1	PASS	0.05	>200	PASS	30/JUNE/2012	PASS	
19492	IEC POWER LEAD	1	PASS	0.04	>200	PASS	30/JUNE/2012	PASS	
19492	IEC POWER LEAD	1	PASS	0.08	>200	PASS	30/JUNE/2012	PASS	
19493	1 GANG EXTENSION LEAD	1	PASS	0.19	>200	PASS	30/JUNE/2012	PASS	
19494	MALE FEMALE IEC POWER LEAD	1	PASS	0.07	>200	PASS	30/JUNE/2012	PASS	
19495	BELKIN 8 GANG IEC EXTENSION LEAD	1	PASS	0.06	>200	PASS	30/JUNE/2012	PASS	
19496	BELKIN 8 GANG IEC EXTENSION LEAD	1	PASS	0.01	>200	PASS	30/JUNE/2012	PASS	
19497	BELKIN 8 GANG IEC EXTENSION LEAD	1	PASS	0.01	>200	PASS	30/JUNE/2012	PASS	
19498	BELKIN 8 GANG IEC EXTENSION LEAD	1	PASS	0.00	>200	PASS	30/JUNE/2012	PASS	
19499	BELKIN 8 GANG IEC EXTENSION LEAD	1	PASS	0.02	>200	PASS	30/JUNE/2012	PASS	
19500	BELKIN 8 GANG IEC EXTENSION LEAD	1	PASS	0.02	>200	PASS	30/JUNE/2012	PASS	
19501	BELKIN 8 GANG IEC EXTENSION LEAD	1	PASS	0.02	>200	PASS	30/JUNE/2012	PASS	

ID NO.	DESCRIPTION	CLASS	VISUAL INSPECTION	TEST		Functional Check	DATE OF NEXT TEST	PASS or FAIL	COMMENTS
				EARTH	INSULATION				
				Ohms	Mohms				
19502	BELKIN 8 GANG IEC EXTENSION LEAD	1	PASS	0.02	>200	PASS	30/JUNE/2012	PASS	
19503	16A SURGE PRO EXTENSION LEAD	1	PASS	0.18	>200	PASS	30/JUNE/2012	PASS	
19504	16A SURGE PRO EXTENSION LEAD	1	PASS	0.10	>200	PASS	30/JUNE/2012	PASS	
19505	SPEAKER	1	PASS	0.00	>200	PASS	30/JUNE/2012	PASS	
19506	SPEAKER	1	PASS	0.01	>200	PASS	30/JUNE/2012	PASS	
19507	30 METRE EXTENSION REEL	1	PASS	0.45	>200	PASS	30/JUNE/2012	PASS	
19508	40 METRE EXTENSION REEL	1	PASS	0.62	>200	PASS	30/JUNE/2012	PASS	
19509	AC ADAPTOR	2	PASS		>200	PASS	30/JUNE/2012	PASS	
19510	SPOT LIGHT	1	PASS	0.09	>200	PASS	30/JUNE/2012	PASS	
19511	SPOT LIGHT	1	PASS	0.03	>200	PASS	30/JUNE/2012	PASS	
19512	SPOT LIGHT	1	PASS	0.01	>200	PASS	30/JUNE/2012	PASS	
19513	SPOT LIGHT	1	PASS	0.00	>200	PASS	30/JUNE/2012	PASS	
19514	DESK LAMP	2	PASS		>200	PASS	30/JUNE/2012	PASS	
19515	DESK LAMP	2	PASS		>200	PASS	30/JUNE/2012	PASS	
19516	AGGRESSOR	1	PASS	0.02	>200	PASS	30/JUNE/2012	PASS	
19517	AGGRESSOR	1	PASS	0.09	>200	PASS	30/JUNE/2012	PASS	
19518	CHAMELEON LIGHT	1	PASS	0.08	>200	PASS	30/JUNE/2012	PASS	
19519	FIESTA LIGHT	1	PASS	0.18	>200	PASS	30/JUNE/2012	PASS	
19520	SUPER LEO LIGHT	1	PASS	0.13	>200	PASS	30/JUNE/2012	PASS	
19521	MALE FEMALE IEC POWER LEAD	1	PASS		>200	PASS	30/JUNE/2012	PASS	
19523	SUPER SCIMITRON	1	PASS	0.07	>200	PASS	30/JUNE/2012	PASS	
19524	RAVE LIGHT	1	PASS	0.14	>200	PASS	30/JUNE/2012	PASS	
19525	LIGHT PROCESSOR	1	PASS	0.09	>200	PASS	30/JUNE/2012	PASS	
19526	4 GANG EXTENSION LEAD	1	PASS	0.03	>200	PASS	30/JUNE/2012	PASS	
19527	MCLELLAND SOUND PROCESSOR	1	PASS	0.18	>200	PASS	30/JUNE/2012	PASS	
19528	IEC POWER LEAD	1	PASS	0.06	>200	PASS	30/JUNE/2012	PASS	
19529	GRAPHIC EQUALIZER	1	PASS	0.06	>200	PASS	30/JUNE/2012	PASS	
19530	IEC POWER LEAD	1	PASS	0.07	>200	PASS	30/JUNE/2012	PASS	
19531	15 CHANNEL ULTRA GRAPHIC	1	PASS	0.08	>200	PASS	30/JUNE/2012	PASS	
19532	IEC POWER LEAD	1	PASS	0.06	>200	PASS	30/JUNE/2012	PASS	
19533	4 CHANNEL COMPRESSOR	1	PASS	0.07	>200	PASS	30/JUNE/2012	PASS	
19534	IEC POWER LEAD	1	PASS	0.04	>200	PASS	30/JUNE/2012	PASS	
19535	2 CHANNEL COMPRESSOR	1	PASS	0.04	>200	PASS	30/JUNE/2012	PASS	
19536	POWER SUPPLY UNIT	2	PASS		>200	PASS	30/JUNE/2012	PASS	
19537	IEC POWER LEAD	1	PASS	0.07	>200	PASS	30/JUNE/2012	PASS	
19538	PHONIC MIXER DECK	1	PASS	0.08	>200	PASS	30/JUNE/2012	PASS	

ID NO.	DESCRIPTION	CLASS	VISUAL INSPECTION	TEST		Functional Check	DATE OF NEXT TEST	PASS or FAIL	COMMENTS
				EARTH	INSULATION				
				Ohms	Mohms				
19539	4 GANG EXTENSION LEAD	1	PASS	0.03	>200	PASS	30/JUNE/2012	PASS	
19540	IEC POWER LEAD	1	PASS	0.01	>200	PASS	30/JUNE/2012	PASS	
19541	CD MIXER DECK	1	PASS	0.02	>200	PASS	30/JUNE/2012	PASS	
19542	IEC POWER LEAD	1	PASS	0.05	>200	PASS	30/JUNE/2012	PASS	
19543	CD PLAYER	1	PASS	0.06	>200	PASS	30/JUNE/2012	PASS	
19544	6 GANG EXTENSION LEAD	1	PASS	0.13	>200	PASS	30/JUNE/2012	PASS	
19545	IEC POWER LEAD	1	PASS	0.04	>200	PASS	30/JUNE/2012	PASS	
19546	MIXER DECK	1	PASS	0.04	>200	PASS	30/JUNE/2012	PASS	
19547	RYGER 403 PRO	1	PASS	0.03	>200	PASS	30/JUNE/2012	PASS	
19548	RYGER TOUCH LIGHT SWITCH	1	PASS	0.04	>200	PASS	30/JUNE/2012	PASS	
19549	DENON CD PLAYER	2	PASS		>200	PASS	30/JUNE/2012	PASS	
19550	4 GANG EXTENSION LEAD	1	PASS	0.04	>200	PASS	30/JUNE/2012	PASS	
19551	IEC POWER LEAD	1	PASS	0.04	>200	PASS	30/JUNE/2012	PASS	
19552	RELOOP DOMINANCE AMP	1	PASS	0.03	>200	PASS	30/JUNE/2012	PASS	
19553	IEC POWER LEAD	1	PASS	0.08	>200	PASS	30/JUNE/2012	PASS	
19554	DV1200 AMP	1	PASS	0.08	>200	PASS	30/JUNE/2012	PASS	
19555	IEC POWER LEAD	1	PASS	0.03	>200	PASS	30/JUNE/2012	PASS	
19556	PV1200 AMP	1	PASS	0.06	>200	PASS	30/JUNE/2012	PASS	
19557	IEC POWER LEAD	1	PASS	0.01	>200	PASS	30/JUNE/2012	PASS	
19558	POWER SUPPLY UNIT	2	PASS		>200	PASS	30/JUNE/2012	PASS	
19631	ACME MAGIC GOBO	1	PASS	0.08	>200	PASS	30/JUNE/2012	PASS	
19632	LED CURTAIN	1	PASS	0.07	>200	PASS	30/JUNE/2012	PASS	
19633	IEC POWER LEAD	1	PASS	0.07	>200	PASS	30/JUNE/2012	PASS	
19634	SONY AC ADAPTOR	2	PASS		>200	PASS	30/JUNE/2012	PASS	
19635	2 GANG EXTENSION LEAD	1	PASS	0.27	>200	PASS	30/JUNE/2012	PASS	
19636	IEC POWER LEAD	1	PASS	0.09	>200	PASS	30/JUNE/2012	PASS	
19637	2 GANG EXTENSION LEAD	1	PASS	0.12	>200	PASS	30/JUNE/2012	PASS	
19638	IEC POWER LEAD	1	PASS	0.09	>200	PASS	30/JUNE/2012	PASS	
19639	IEC POWER LEAD	1	PASS	0.19	>200	PASS	30/JUNE/2012	PASS	
19640	IEC POWER LEAD	1	PASS	0.19	>200	PASS	30/JUNE/2012	PASS	
19641	4 GANG EXTENSION LEAD	1	PASS	0.19	>200	PASS	30/JUNE/2012	PASS	
19642	IEC POWER LEAD	1	PASS	0.05	>200	PASS	30/JUNE/2012	PASS	
19643	2 GANG EXTENSION LEAD	1	PASS	0.21	>200	PASS	30/JUNE/2012	PASS	
19644	2 GANG EXTENSION LEAD	1	PASS	0.12	>200	PASS	30/JUNE/2012	PASS	
19645	30 METRE EXTENSION REEL	1	PASS	0.51	>200	PASS	30/JUNE/2012	PASS	
19646	STARVILLE SPOT LIGHT	1	PASS	0.14	>200	PASS	30/JUNE/2012	PASS	

ID NO.	DESCRIPTION	CLASS	VISUAL INSPECTION	TEST		Functional Check	DATE OF NEXT TEST	PASS or FAIL	COMMENTS
				EARTH	INSULATION				
				Ohms	Mohms				
19647	STARVILLE SPOT LIGHT	1	PASS	0.15	>200	PASS	30/JUNE/2012	PASS	
19648	SPOT LIGHT	1	PASS	0.18	>200	PASS	30/JUNE/2012	PASS	
19649	SPOT LIGHT	1	PASS	0.09	>200	PASS	30/JUNE/2012	PASS	
19650	SPOT LIGHT	1	PASS	0.08	>200	PASS	30/JUNE/2012	PASS	
19651	SPOT LIGHT	1	PASS	0.08	>200	PASS	30/JUNE/2012	PASS	
19652	IEC POWER LEAD	1	PASS	0.03	>200	PASS	30/JUNE/2012	PASS	
19653	SPOT LIGHT	1	PASS	0.08	>200	PASS	30/JUNE/2012	PASS	
19654	SPOT LIGHT	1	PASS	0.08	>200	PASS	30/JUNE/2012	PASS	
19655	4 CHANNEL DIGITAL DIMMER	1	PASS	0.13	>200	PASS	30/JUNE/2012	PASS	
19656	SUPER LEO LIGHT	1	PASS	0.15	>200	PASS	30/JUNE/2012	PASS	
19657	SUPER LEO LIGHT	1	PASS	0.10	>200	PASS	30/JUNE/2012	PASS	
19658	CYBERBEAM LIGHT	1	PASS	0.10	>200	PASS	30/JUNE/2012	PASS	
19659	BUBBLE MACHINE	1	PASS	0.04	>200	PASS	30/JUNE/2012	PASS	
19660	TECHNICS 1210	2	PASS		>200	PASS	30/JUNE/2012	PASS	
19661	TECHNICS 1210	2	PASS		>200	PASS	30/JUNE/2012	PASS	
19662	NUMARK TT650	2	PASS		>200	PASS	30/JUNE/2012	PASS	
19663	NUMARK TT650	2	PASS		>200	PASS	30/JUNE/2012	PASS	
19664	ORCST AMPLIFIER	1	PASS	0.06	>200	PASS	30/JUNE/2012	PASS	
19665	IEC POWER LEAD	1	PASS	0.05	>200	PASS	30/JUNE/2012	PASS	
19666	SHARKY SMOKE MACHINE	1	PASS	0.10	>200	PASS	30/JUNE/2012	PASS	
19667	POWERED SPEAKER	1	PASS	0.12	>200	PASS	30/JUNE/2012	PASS	
19668	UV 400 LIGHT	1	PASS	0.06	>200	PASS	30/JUNE/2012	PASS	
19669	BEHRINGER EURODESK MIXER	1	PASS	0.14	>200	PASS	30/JUNE/2012	PASS	

**TOTAL APPLIANCES: 121**

TEST ENGINEER SIGNATURE:

TEST ENGINEER NAME: ANDY LANGHAM